

Question 87:

The cleaning and purging of flammable gas piping system should be in accordance with which standard?

Possible Choices:

NFPA 10

NFPA 13

NFPA 13R

NFPA 13D

NFPA 56

NFPA 70

State Fire Prevention Code

None of the choices. .

Answer:

The cleaning and purging of flammable gas piping system should be in accordance with NFPA 56.